



## UTHV.S24913 Heat-actuated Devices for Special Application

[Page Bottom](#)

---

### Heat-actuated Devices for Special Application

[See General Information for Heat-actuated Devices for Special Application](#)

#### LGM PRODUCTS LTD

S24913

18 RIVERSIDE PARK INDUSTRIAL ESTATE  
DOGFLUD WAY  
FARNHAM, GU9 7UG UNITED KINGDOM

**Fixed temperature line type heat detector cables for indoor/outdoor use, "Signaline"**, Model(s) FT105 (rated 105 C/221 F)(a), FT105-R (rated 105 C/221 F)(b), FT68 (rated 68 C/155 F)(a), FT68-R (rated 68 C/155 F)(b), FT88 (rated 88 C/190 F)(a), FT88-R (rated 88 C/190 F)(b)

(a) - Distance between lines of heat detecting cable on smooth ceilings with large bays shall not be more than 35 ft. Distance between heat detecting cable from any wall or partition shall not be more than 17.5 ft.

(b) - Distance between lines of heat detecting cable on smooth ceilings with large bays shall not be more than 15 ft. Distance between heat detecting cable from any wall or partition shall not be more than 7.5 ft.

Note - Intended to be connected to a UL Listed control unit. Models are also complimentary Listed as a heat-automatic fire detector (UQGS).

[Last Updated](#) on 2010-03-19

---

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

Copyright © 2010 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2010 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.





## UQGS.S24913 Heat-automatic Fire Detectors

[Page Bottom](#)

### Heat-automatic Fire Detectors

[See General Information for Heat-automatic Fire Detectors](#)**LGM PRODUCTS LTD**

S24913

18 RIVERSIDE PARK INDUSTRIAL ESTATE  
DOGFLUD WAY  
FARNHAM, GU9 7UG UNITED KINGDOM

Model No.	Type	Compatibility Restrictions	Contact Arrangement	Temp Range (°F)	Spacing (Ft)	
					Smooth Ceiling	to Wall or Partition
<b>FT105</b>	FT, HSC	None	NO	221	35	17.5
<b>FT105-R</b>	FT, HSC	None	NO	221	15	7.5
<b>FT68</b>	FT, HSC	None	NO	155	35	17.5
<b>FT68-R</b>	FT, HSC	None	NO	155	15	7.5
<b>FT88</b>	FT, HSC	None	NO	190	35	17.5
<b>FT88-R</b>	FT, HSC	None	NO	190	15	7.5

FT - Fixed temperature

HSC - Heat sensitive cable

Note - Complementary Listed as a heat actuated device for special applications (UTHV).

[Last Updated](#) on 2010-03-19[Questions?](#)[Notice of Disclaimer](#)[Page Top](#)

Copyright © 2010 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2010 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

